




(94)
C-b-222



304-401 YORK AVE., WINNIPEG 1
TELEPHONE 946-7756 If no answer call 946-7982

March 2nd, 1971.

ORDINARY LICENCE - **HNAKSA FISH TRAINING CENTRE**
DEPARTMENT OF MINES AND NATURAL RESOURCES,
Fish Training Centre, S $\frac{1}{2}$ of Section 21-22-4E,
Rural Municipality of Bifrost

This licence is issued pursuant to The Clean Environment Act permitting the Department of Mines and Natural Resources to discharge contaminants or wastes arising from the operation of a sewage lagoon consisting of two (2) cells, located on the S $\frac{1}{2}$ of Section 21-22-4E in the Rural Municipality of Bifrost, into Lake Winnipeg, subject to the following conditions:

- (1) The licensee shall ensure that each cell of the said sewage lagoon is constructed in such a manner as to prevent contamination of groundwater.
- (2) The licensee shall ensure that the contaminants or wastes collected and retained in the said sewage lagoon are so treated that the level of the biochemical oxygen demand of the effluent does not exceed 30 milligrams per litre at the time of release to Lake Winnipeg.
- (3) The licensee shall ensure that before the release of effluent takes place to Lake Winnipeg the contaminants or wastes collected and retained in the said sewage lagoon are chlorinated to a standard acceptable to the Clean Environment Commission.
- (4) The licensee shall ensure that no discharge of effluent takes place between the first of November in any one year and the fifteenth of May the following year without the express permission of the Commission.
- (5) The licensee shall ensure that no discharge of effluent takes place between the fifteenth day of June and the fifteenth day of September in any one year without the express permission of the Commission.


*Assigned to
Cory's office
19 Feb 72
Wmm*

..... 2

Ordinary Licence -
Department of Mines & Natural Resources,
Fish Training Centre

Page - 2 -

- (6) The licensee shall ensure that the said sewage lagoon is operated in such a manner as to minimize the release of offensive odours.
- (7) The licensee shall ensure that the biochemical oxygen demand loading on the primary cell(s) of the said sewage lagoon does not exceed 50 pounds per acre per day.



Chairman,
Clean Environment Commission.

CANCELLED

CC-Reg. Services
Aug 28/73