

*Binder Copy*

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION  
UNDER THE CLEAN ENVIRONMENT ACT

---

RE: THE CLEAN ENVIRONMENT COMMISSION and PIONEER MEAT LTD., Applicant,

- WHEREAS pursuant to the provisions of The Clean Environment Act, Pioneer Meat Ltd. filed an application with the department in connection with the operation of abattoir waste disposal pits and a sewage lagoon system located on the north side of PTH No. 421 in part of Section 34, Township 1, Range 1, WPM, in the Rural Municipality of Rhineland, Manitoba;
- AND WHEREAS in the absence of limits, terms and conditions prescribed by a regulation under the said Act, the application was referred to The Clean Environment Commission to prescribe limits, terms and conditions;
- AND WHEREAS after giving notice of the application, the Commission did not receive any representations from persons likely to be affected by an order of the Commission issued in connection with the application;
- AND WHEREAS the Commission considered the application on the 20th day of September, 1982;

IT IS HEREBY ORDERED THAT

1. The Applicant shall not discharge effluent from the said sewage lagoon system:
  - (a) where the organic content of the effluent, as indicated by the five day biochemical oxygen demand, is in excess of 30 milligrams per litre;
  - (b) where the faecal coliform content, as indicated by the MPN index, is in excess of 200 per 100 millilitres of sample.
2. The Applicant shall not discharge effluent from the said sewage lagoon system between the 1st day of November of any year and the 15th day of May of the following year.
3. The Applicant shall operate and maintain all components of the said operation in such a manner that the release of offensive odours is minimized so as not to create a nuisance conditions or public annoyance beyond the property line of the said operation.


*Assigned  
to  
W.P.C  
Sept 29/82*

4. The Applicant shall dispose of solid wastes and sludge from the said operation in an innocuous manner and at a location satisfactory to the Environmental Management Division of the department.
5. On or before the 1st day of July, 1983, the Applicant shall construct and install a dyke with valved culvert at the south end of the storage pond of the said sewage lagoon system sufficient to provide the means for control of the discharge of any effluent from the said system.

Order No. 961

Dated at the City of Winnipeg

this 28th day of September, 1982.

  
Chairman,  
The Clean Environment Commission.

File: 2425.0