



Conservation and Water Stewardship

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg Manitoba R3C 1A5
T 204 945-8321 F 204-945-5229
www.gov.mb.ca/conservation/eal

Client File No. 1957.20

January 8, 2016

Luc Lahaie
Chief Administrative Officer
Rural Municipality of Hanover
28 Westland Drive
Box 1720
Steinbach, MB R5G 1N4
Email: general@hanovermb.ca

Dear Mr. Lahaie:

Re: Blumenort wastewater treatment lagoon - wastewater effluent limit for phosphorus in effect January 1, 2016

As you have been previously notified, your wastewater treatment lagoon at Blumenort is required to meet the 1 mg/L phosphorus limit as of January 1, 2016 in accordance with the Water Quality Standards, Objectives and Guidelines Regulation under *The Water Protection Act*.

Your wastewater treatment lagoon for the Community of Blumenort operates under Environment Act Licence 2550. In addition to meeting the 1 mg/L phosphorus limit and in accordance with Clause 2 and 33 of Licence 2550, you are hereby required to sample, analyze and report on the total phosphorus content of your wastewater effluent prior to discharging to surface water.

Should you have questions, please call Rob Boswick at 204-945-6030.

Yours sincerely,

“original signed by”

Tracey Braun, M.Sc.
Director

c: Don Labossiere/Donna Smiley, Environmental Compliance and Enforcement Branch
Nicole Armstrong, Director, Water Science and Management Branch
Rob Boswick, Environmental Approvals Branch
Public Registries