

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg, Manitoba R3C 1A5
T 204 945-8321 F 204 945-5229
www.gov.mb.ca/sd/eal

CLIENT FILE NO.: 5435.10

October 11, 2017

Jolene Bird
Chief Administrative Officer
Rural Municipality of Montcalm
Box 300
Letellier MB R0G 1C0

Dear Ms. Bird:

**Re: St. Jean Baptiste Wastewater Treatment Lagoon – Liner Approval
Environment Act Licence No. 3108**

This is further to liner test results for the above facility provided by David Kelly of JR Cousin Consultants Ltd. on October 10, 2017. The liner's hydraulic conductivity meets the requirements of Clause 20 of the above licence, and so approval to operate the facility is provided pursuant to Clause 23 of the Licence.

As required by Clause 18 of the Licence, record drawings for the facility are due within four months of the date of this letter.

If you have any questions regarding this matter, please contact me at (204) 945-7021 or at Bruce.Webb@gov.mb.ca.

Yours truly,



Bruce Webb, P. Eng.
Water Development and Control
Assessment Officer
Environmental Approvals Branch

c: David Kelly, P. Eng., JR Cousin Consultants Ltd.
Don Labossiere/Donna Smiley, Environmental Compliance and Enforcement Branch
Tyler Kneeshaw, Environmental Compliance and Enforcement Branch
Public Registries