

Upgrade Schedule 2 – Underground Storage Tank Systems¹ Containing Used Oil

Permit Expiry Date	Upgrading Requirements
<i>Existing Underground Storage Tank System not Equipped with Approved Corrosion Protection</i>	
June 30, 2005	Precision Leak Test or remove product from System
October 31, 2005	<p>If Precision Leak Test is not performed, System to be removed</p> <p>If the Storage Tank System passes precision leak test, System may continue to operate until October 31, 2006</p>
October 31, 2006	Storage Tank System to be withdrawn from service and removed
<i>Existing Underground Storage Tank with Approved Corrosion Protection</i>	
December 31, 2008	<p>Underground product and vent lines without corrosion protection must be</p> <ul style="list-style-type: none"> • replaced² <p>or</p> <ul style="list-style-type: none"> • entire Storage Tank System to be withdrawn from service and removed
December 31, 2010²	<p>Suction pipe in compliance with the CCME Code of Practice³</p> <p>Liquid and vapour-tight connections, caps, and adapters at suction pipe(s)</p> <p>Spill containment device in compliance with the CCME Code of Practice³</p> <p>Overfill protection device in compliance with the CCME Code of Practice³</p> <p>Venting in compliance with the CCME Code of Practice³</p>
December 31, 2010 or No Expiry Date	Leak detection in compliance with the CCME Code of Practice ³

¹A partially buried storage tank is considered neither an aboveground nor underground storage tank and shall be withdrawn from service and removed by June 30, 2006.

²When underground piping is replaced; the installation must be upgraded to include, as per the Code³:

- A suction pipe
- Spill containment device
- An overfill protection device
- Proper venting
- Liquid and vapour-tight connections, caps and adapters at suction pipe(s)

³the 'Code' is the Environmental Code of Practice for Aboveground and Underground Storage Tank Systems Containing Petroleum and Allied Petroleum Products, published by the Canadian Council of Ministers of the Environment, 2003, PN1326.