A Safe Workplace A Workplace Safety and Health Manual for Your Community

1			-
Section:	Rules Procedures, Practices		Page 1 of 2
III-D	and Guidelines	Approved By: Harvey Bostrom	
Subject:	Assembling and Using	Effective: April 01, 2005	
TSE-14	Scaffolds	Revised: April 1, 2011	

Refer to part 28, Scaffolds and other Elevated Work Platforms of *The Manitoba Workplace Safety and Health Act and Regulations*.

PPE Required: Safety harness, steel- toe boots, gloves, hard hat.

Scaffolding is only to be used and assembled by trained and competent employees.

Platform Scaffolds:

- Except for short duration that can be done safely from a ladder, an employer must ensure that a worker engaged in work that cannot be done from the ground or other safe elevation is provided with a scaffold or an elevated platform.
- An employer must ensure that a commercially manufactured scaffold or elevated platform is installed, used, maintained and dismantled in accordance with the manufacturer's specifications.
- If a scaffold is more than 6m in height, it is equipped with a suitable hoisting device for hoisting materials.
- Employer must ensure that scaffolding complies with the requirements of CAN/CSA S269.2- M87 (R2003) *Access Scaffolding for Construction Purposes.*

Steps:

- 1. Inspect all components and replace any defective parts.
- 2. Assemble all components from the ground up. Do not use on ice or snow or slippery surfaces without non-skid devices or securing feet.
- 3. Scaffold must be installed plumb and stabilized by bracing the horizontal and vertical members to prevent lateral movement.
- 4. Scaffold must be anchored to building at 15 feet (4.57M) above ground level and at 15 feet (4.57M) intervals vertically and at 20 feet (6.1M) intervals horizontally.
- 5. Scaffold planks made of wood shall be at least nominal size no. 1 construction grade 2" x 10" (50mm x 250mm) (S-P-F).
- 6. Scaffold planks made of wood shall not span more than 8 feet (2.5M).

A Safe Workplace A Workplace Safety and Health Manual for Your Community

Section:	Rules Procedures, Practices		Page 2 of 2
III-D	and Guidelines	Approved By: Harvey Bostrom	
Subject:	Assembling and Using	Effective: April 01, 2005	
TSE-14	Scaffolds	Revised: April 1, 2011	

- 7. Scaffolding platforms shall be at least 19.7 inches (500mm) wide.
- 8. Scaffold planks shall extend past ledgers or end frames not less than 5.9 inches (150mm) or more than 11.8 inches (300mm).
- 9. Overlapping planks extend must be centered directly over and at least 11.8 inches (300mm) beyond the end supports of a scaffold
- 10. Secure planks to the scaffold frame with bolts.
- 11. Guardrails shall be a minimum of 36 inches (914mm) high and not more than 42 inches (1067mm).
- 12. Toe boards are to be installed on the opening side of the platform were there is a risk of tools, materials, equipment and debris falling from the platform.
- 13. Use *Fall Protection Procedure* (section III-C, G-12) and devices when mounting, dismounting, working on or disassembling scaffolding. Never work alone on scaffolding.
- 14. Keep area under and around scaffolding free from debris and section off area around scaffold to protect persons from falling debris.
- 15. Never over reach from scaffolding guard rails. Keep deck clear of debris to prevent tripping.
- 16. Never remain on a mobile scaffold when it is being moved.
- 17. Disassemble scaffolding in reverse order after work is completed.