

# Environment Act Licence

Manitoba  
Environment



Licence No. 1656 R  
Issue Date APRIL 8, 1993  
(REVISED: JULY 29, 1993)

In accordance with the Manitoba Environment Act (C.C.S.M. c.E125)

THIS LICENCE IS ISSUED TO:

## TOWN OF MORDEN: "the Licencee"

for the Development being a Water Treatment Plant (Wastewater) located on Lot 2, Plan 2424 MLTO in Section 6, Township 3, Range 5 WPM, with discharge of supernatant to the Dead Horse Creek, and the final disposal of dewatered sludge at the Town of Morden waste disposal ground located in Section 10, Township 3, Range 6 WPM, and subject to the following specifications, limits, terms and conditions:

### DEFINITIONS

In this Licence,

"Director" means a Director designated under Environment Act.

"Sludge dewatering beds" means the facility for the separation of the sludges wasted from the Town of Morden water treatment plant.

### GENERAL SPECIFICATIONS

1. The Licencee shall ensure that domestic wastewater is not directed to the sludge dewatering beds.
2. The Licencee shall ensure that laboratory wastes are not directed to the sludge dewatering beds.
3. The Licencee shall, in case of physical or mechanical breakdown of the sludge dewatering beds:
  - (a) notify the Director immediately;
  - (b) identify the repairs required to the wastewater collection and/or treatment system; and
  - (c) complete the repairs in accordance with the written instructions of the Director.

4. Unless otherwise specified, all laboratory analyses shall be conducted in accordance with the latest edition of "Standard Methods For The Examination Of Water and Wastewater."

#### LIMITS, TERMS, AND CONDITIONS

5. The Licencee shall not discharge effluent from the sludge dewatering beds where
- (a) the suspended solids of the effluent is in excess of 25 milligrams per litre; and
  - (b) the discharge of effluent will cause or contribute to flooding along the receiving watercourse including but not limited flooding caused by ice formation channel capacity reduction along the watercourse attributed to the discharge.

#### CONSTRUCTION SPECIFICATIONS

6. The Licencee shall, prior to the construction of the dikes for the sludge dewatering beds, remove all organic topsoil from the area where the dikes will be constructed.
7. The Licencee shall ensure that seepage from the Development will not cause or contribute to flooding along the receiving watercourse including but not limited flooding caused by ice formation channel capacity reduction along the watercourse attributed to the seepage.

#### REVIEW OR REVOCATION

8. If in the opinion of the Director the Licencee has exceeded or is exceeding the specifications, limits, terms, or conditions set out herein, the Director may revoke, temporarily or permanently, this Licence.



Larry Strachan, P. Eng.  
Director, Environment Act