

# Environment Act Licence

Manitoba  
Environment



Licence No. 2043  
Issue Date May 25, 1995

In accordance with the Manitoba Environment Act (C.C.S.M. c. E125)

THIS LICENCE IS ISSUED TO:

**MANITOBA HYDRO: " the Licencee"**

subject to the following specifications, limits, terms and conditions for the construction, operation, and maintenance of the Development known as the Churchill Spaceport 138 kV Transmission Line. The Development involves the construction of a 138 kV transmission line beginning at a tap off the existing Radisson-Churchill 138 kV transmission line at a point approximately 10 kilometers south of the Churchill South Station and proceeding in a northeasterly direction for a distance of 20.4 kilometers terminating at the Spaceport Station.

**SPECIFICATIONS, LIMITS, TERMS AND CONDITIONS**

- 1) The Licencee shall construct the Development in accordance with the *Churchill - Spaceport 138 kV Transmission Line Environmental Impact Statement, March 1995*, filed in support of the Environment Act Proposal, dated March 10, 1995.
- 2) The Licencee shall submit to the Director prior to commencement of construction activities of the Development, a *Churchill - Spaceport 138 kV Transmission Project Environmental Protection Plan*. The plan shall describe the approach to be used by the Licencee to monitor environmental conditions both during and after construction in order to ensure that impact management specified in the *Churchill - Spaceport 138 kV Transmission Line Environmental Impact Statement*, is applied systematically and in manner consistent with the commitments made in the Environmental Impact Statement.
- 3) The Licencee shall, during the selective clearing of the right-of-way, exercise caution in the use of heavy equipment in order to minimize impacts on vegetation.
- 4) The Licencee shall, during maintenance of the Development, use mechanical and other non-chemical means to control vegetation growth.
- 5) The Licencee shall, during construction of the Development, ensure that any fuel storage areas are located at a minimum distance of 100 metres away from waterbodies, and ensure the storage areas comply with the requirements of *Manitoba Regulation 97/88R - Storage and Handling of Gasoline and Associated Products Regulation*.

