

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and the LOCAL GOVERNMENT DISTRICT OF LYNN LAKE, Applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, Mr. E.H. Hanson of Underwood, McLellan & Associates Limited, applied to The Clean Environment Commission, on behalf of the Local Government District of Lynn Lake, to prescribe limits in connection with the operation of an aerated sewage lagoon system located 2,000 feet South of the Lynn Lake townsite in the Local Government District of Lynn Lake, Manitoba,

AND WHEREAS no representation was made to the said Commission by any person who is, or is likely to be, affected by an Order of the Commission prescribing limits in connection with the said operation,

AND WHEREAS the said Commission considered the application on the 15th day of October, 1974,

IT IS HEREBY ORDERED THAT

1. The Applicant shall ensure that all facilities for the treatment of sewage are so constructed, maintained and operated as to:
 - (a) prevent the contamination of groundwater, and
 - (b) minimize the release of offensive odours,
2. The Applicant shall ensure that the biochemical oxygen demand loading of the said system does not exceed 700 pounds per day,
3. The Applicant shall ensure that, with respect to effluent from the said system:

*Assigned to Water Pollution Control
Nov 22/74
AN/BY*

3. cont'd . . .

- (a) the five-day biological oxygen demand of the effluent does not exceed 30 milligrams per litre,
- (b) the suspended solids in the effluent do not exceed 30 milligrams per litre,
- (c) there is continuous chlorination to ensure retention of not less than 0.5 milligrams of chlorine per litre, after 15 minutes contact, before the effluent is released into the Lynn River,

IT IS HEREBY FURTHER ORDERED THAT


- 4. The Applicant shall ensure that any sludge removed from the said system is subject to disposal in accordance with instructions issued by the Environmental Management Division of the Department of Mines, Resources and Environmental Management,

5. The Applicant shall ensure that samples of the influent and effluent of the said system are extracted and submitted in accordance with instructions issued by the said Environmental Management Division,
6. The Applicant shall ensure that the quantity of influent to the said system is measured and recorded daily,
7. The Applicant shall ensure that samples of the said effluent are analysed daily with respect to the amount of residual chlorine content,
8. The Applicant shall ensure that the measurements of quantity and records of analysis data required by Clauses 6 and 7 are submitted to the said Environmental Management Division within thirty days of the end of the calendar month in which they were taken.

Order No. 412

Dated at the City of Winnipeg

this 19th day of NOVEMBER, 1974.



Chairman,
Clean Environment Commission